



BIDS AND A WARDS COMMITTEE

BID BULLETIN NO. 1

Supply, Delivery and Installation of Solar Powered System Backup for INSPIRE Beneficiaries in Bicol Region under Livestock and Poultry Program

May 17, 2024

This Bid Bulletin is issued to clarify, modify or amend items in the Bidding Documents. Accordingly, this shall form an integral part of the said Documents.

PARTICULAR	AMENDMENTS / CLARIFICATIONS
<p>Section I. Invitation to Bid Section VII. Technical Specifications</p> <p>Partial Bid is not allowed.</p> <hr/> <p>Delivery of the Goods 180 days upon receipt of NTP</p> <hr/> <p>Bidding Documents Fee ₱25,000.00</p>	<p>Section I. Invitation to Bid Section VII. Technical Specifications</p> <p>Partial Bid is allowed.</p> <p>Lot 1: ABC - ₱3,000,000.00 3 units - Camarines Norte</p> <p>Lot 2: ABC - ₱8,000,000.00 8 units - Camarines Sur</p> <p>Lot 3: ABC - ₱5,000,000.00 3 units - Albay 2 units - Catanduanes</p> <p>Lot 4: ABC - ₱4,000,000.00 2 units - Masbate 2 units - Sorsogon</p> <hr/> <p>Delivery of the Goods 45 days upon receipt of NTP</p> <hr/> <p>Bidding Documents Fee Lot 1 - ₱5,000.00 Lot 2 - ₱10,000.00 Lot 3 - ₱5,000.00 Lot 4 - ₱5,000.00 20,000.00 if all lots</p>
<p>Section II. Instructions to Bidders</p> <p>5.3 Pursuant to Section 23.4.1.3 of the 2016 revised IRR of RA No.9184, the Bidder shall have an SLCC that is at least one (1) contract similar to the Project the value of which, adjusted to current prices using the PSA's CPI, <u>must be at least 50% of the ABC in the amount of Php10,000,000.00</u></p>	<p>Section II. Instructions to Bidders</p> <p>5.3 Pursuant to Section 23.4.1.3 of the 2016 revised IRR of RA No.9184, the Bidder shall have an SLCC that is at least one (1) contract similar to the Project the value of which, adjusted to current prices using the PSA's CPI, <u>must be at least 50% of the ABC in the amount of:</u></p> <p>Lot 1 - 1,500,000.00 Lot 2 - 4,000,000.00 Lot 3 - 2,500,000.00 Lot 4 - 2,000,000.00 Total - 10,000,000.00</p>



Republic of the Philippines
REGIONAL FIELD OFFICE NO. 5
San Agustin, Pili, Camarines Sur

Section VII. Technical Specifications	Section VII. Technical Specifications
After Sales Servicing: conduct quarterly site visit, monitoring, inspection, system check-up and emergency repair.	After Sales Servicing: conduct quarterly site visit, visual inspection and educational maintenance lecture for a period of one (1) year.
Design Inverter: 8kw Hybrid Max. DC Input Power: 10,400 W	Design Inverter: 10kw Hybrid Max. DC Input Power: 13,500W

The Secretariat is hereby directed to inform all prospective bidders for the concerned projects and post a copy of the same in PhilGeps, designated Bid Bulletin Board and in the agency website.

For guidance and information of all concerned.

(Signed)
LORENZO L. ALVINA
Chief, Integrated Laboratory Division
BAC Chairperson